



liftinstituut
SINCE 1933

TYPE EXAMINATION CERTIFICATE FOR LIFTCOMPONENTS

Issued by Liftinstituut B.V.

Certificate no. : NL11-400-1002-125-04 Revision no.: 3
Description of the product : Door contact for manually operated swing doors
Trademark : Prudhomme
Type no. : CA / STN
Name and address of the manufacturer : Prudhomme S.a.
38 rue Charles de Gaulle
94140 Alfortville
France
Name and address of the certificate holder : Prudhomme S.a.
38 rue Charles de Gaulle
94140 Alfortville
France
Certificate issued on the following requirements : Not applicable
Certificate based on the following standard : Parts of: EN81-1/2 :1998 + A3:2009, EN 60947-1:2007 + A1:2011, EN 60947-5-1:2004 + A1:2009, EN81-20:2020
Test laboratory : None
Date and number of the laboratory report : None
Date of type examination : January 2023
Additional document with this certificate : Report belonging to the type examination certificate no.: NL11-400-1002-125-04 Rev.3
Additional remarks : U_e 230 VAC I_e 2.0 A (AC)
200 VDC 1.0 A (DC)
Utilization category AC-15 / DC-13 U_i 500 V
 U_{imp} 4 kV I_{th} 12 A
Furthermore see chapter 5 of the report belonging to this type examination certificate.
This revision replaces certificate NL11-400-1002-125-04 Rev.2 of 01-08-2017
Conclusion : The product meets the requirements / standards referred to in this certificate taking into account any additional remarks mentioned above.

Certification decision by

W.G. Kasteleijn
Product Manager Certification

Amsterdam

Date : 16-01-2023

Valid until : 16-01-2028